



2022 Consumer Confidence Report for Public Water System THE CONSOLIDATED WSC CENTRAL SYSTEM

This is your water quality report for January 1 to December 31, 2022.

THE CONSOLIDATED WSC CENTRAL SYSTEM provides treated surface water from Houston County Lake located in Houston County, Texas.

For more information regarding this report contact:

Name Amber Stelly – General Manager

Phone (936)-544-2986

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (936)- 544-2986

Definitions and Abbreviations

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

THE CONSOLIDATED WSC CENTRAL SYSTEM purchases treated water from HOUSTON COUNTY WCID 1. HOUSTON COUNTY WCID 1 provides purchased surface water from Houston County Lake located in Houston County, Texas. TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact Amber Stelly at 936-544-2986.

2022 Water Quality Test Results

The following constituents were detected by Houston County WCID 1.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual	MCLG	MCL	Units	Violation?	Likely Source of Contamination
Total Barium	2022	0.04	0.04– 0.04	2	2	ppm	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2022	0.4909	0.3 - 0.8	4.0	4.0	ppm	NO	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Chromium	2022	<0.001	<0.001	0.1	0.1	ppm	NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge run off from waste batteries

Turbidity

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. It is a good indicator of water quality and the effectiveness of filtration systems and disinfectants.

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	0.55 NTU	1 NTU	NO	Soil runoff.
Yearly percent of samples meeting limits	99.589%	95%	NO	Soil runoff.

Secondary and Other Constituents

Secondary constituents are not necessarily cause for health concerns but may cause taste, color and odor problems.

Constituent	Year	Average Level	Range of Levels Detected	Secondary Limit	Unit of Measure	Violation?	Source in Drinking Water
Aluminum, Total	2022	0.067	0.067 – 0.067	0.2	ppm	NO	Water additive used to control microbes.
Bicarbonate	2022	23.8	23.8 – 23.8	na	ppm	NO	Corrosion of carbonate rocks such as limestone.
Calcium, Total	2022	14.7	14.7 – 14.7	na	ppm	NO	Abundant naturally occurring element.
Chloride	2022	13.5	13.5 – 13.5	250	ppm	NO	Abundant naturally occurring element; Used in water purification; by-product
Magnesium, Total	2022	2.38	2.38- 2.38	na	ppm	NO	Abundant naturally occurring element.

pH	2022	8.13	7.0 – 8.9	9	units	NO	Measure of the acidity or basicity of water.
Sodium, Total	2022	5.63	5.63 – 5.63	na	ppm	NO	Erosion of natural deposits; By-product of oil field activity.
Sulfate	2022	22.5	22.5– 22.5	250	ppm	NO	Naturally occurring; Common industrial by-product; By-product of oil field
Alkalinity, Total	2022	23.8	23.8- 23.8	na	ppm	NO	Naturally occurring soluble mineral salts.
Total Dissolved	2022	106	106 - 106	500	ppm	NO	Total dissolved mineral constituents in water.
Total Hardness as	2022	46.6	46.6 - 4 6.6	na	ppm	NO	Naturally occurring calcium.
Zinc, total	2022	0.0074	0.0058 - 0.0058	5	ppm	NO	Moderately abundant naturally occurring element used in the metal industry.

2022 Water Quality Test Results

The following constituents were detected by Consolidated WSC.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2022	37	16.6 - 42.5	No goal for the total	60	ppb	NO	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2022	59	32 - 70.1	No goal for the total	80	ppb	NO	By-product of drinking water disinfection.
-------------------------------------	------	----	-----------	-----------------------	----	-----	-----------	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2022	0.206	0.0133 - 0.206	10	10	ppm	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/14/2021	1.3	1.3	0.14	0	ppm	NO	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/14/2021	0.015	0.015	0.0011	0	ppb	NO	Corrosion of household plumbing systems; Erosion of natural deposits.

Coliform Bacteria

We performed 147 bacteriological tests on your water. No E. coli was detected.

Maximum Contaminant Level	Total Coliform Maximum	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	0	0	NO	Naturally present in the environment.

Disinfectant Residual

We are required by law to maintain a minimum of 0.5 mg/L chlorine residual at all points of the distribution system. We take on average 14,000 yearly tests confirming we meet this quality standard

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Total Chlorine	2022	2.02	0.74 – 3.79	4	4	ppm	NO	Water additive used to control microbes.